



Confidential Report

Our Ref: 27/04729B/08/18



1066

Notified Body
for PPE Directive,
Construction Products Regulation
& Marine Equipment Directive
I.D. No. 0338 & 0339

Date: 20 September 2018

Our Ref: 27/04729B/08/18

Your Ref:

Page: 1 of 6

Client: GTECH Strategies Limited

1 Introduction

This classification report defines the classification assigned to 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard (as described by the sponsor) in accordance with the procedures given in EN 13501-1:2007+A1:2009.

CLASSIFICATION OF REACTION TO FIRE IN ACCORDANCE WITH BS EN 13501-1:2007+A1:2009

Sponsor: GTECH Strategies

Prepared by: BTTG Testing & Certification Ltd

Product name: 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard

Manufacturer: Arlon Graphics LLC, USA.

Classification report no.: 27/04729A/08/18

Issue number: 1

Date of issue: 20 September 2018

This classification report consists of five pages and may only be used or reproduced in its entirety.

Note: This report relates only to the samples submitted and as described in the report.



Date: 20 September 2018

Our Ref: 27/04729B/08/18
Your Ref:

Page: 2 of 6

Client: GTECH Strategies Limited

2 Details of classified product

2.1 General

The product, 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard, is defined as a type of product according to BS EN 15102.

2.2 Product description

The product, 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard, is described below as:-

Reference: 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard
Manufacturer: Arlon Graphics LLC, USA.
Product Type: Wallcovering

3 Reports and results in support of this classification

3.1 Reports

Name of Laboratory	Name of sponsor	Report ref. no.	Test method and date Field of application rules and date"
BTTG T & C Ltd	GTECH Strategies Limited	27/04729A/08/18	BS EN 11925-2:2010 BS EN 13823:2010



1066

Shirley® Technologies Limited. Registered Office: Wira House, West Park Ring Road, Leeds, LS16 6QL.
A company registered in England & Wales with company number 04669651. VAT Number GB 816764800.

BTTG™ and Shirley® are trade names of Shirley Technologies Limited.

The supply of all goods and services is subject to our standard terms of business, copies of which are available on request.
Our laboratories are accredited to EN ISO/IEC 17025.

Copyright © 2016 Shirley Technologies Limited. All rights reserved.

Date: 20 September 2018

Our Ref: 27/04729B/08/18
 Your Ref:

Page: 3 of 6

Client: GTECH Strategies Limited

3.2 Results

Test method and test number	Parameter	No. Tests (specimens)	Results	
			Continuous parameter - mean (m)	Compliance with Class C _{FL} -s1 parameters
BS EN 11925-2:2010	FS (mm)	6	<150mm within 60s	Compliant
	Flaming Droplets / particles		No	Compliant
BS EN 13823:2010	FIGRA _{0.2MJ} (W/s)	3	232.0	Compliant
	FIGRA _{0.4MJ} (W/s)		166.9	
	THR _{600s} (MJ)		2.0	Compliant
	LFS to edge (yes or no)		No	
	SMOGR (m ² /s ²)		0.0	
	TSP _{600s} (m ²)		42.6	
	FDP flaming ≤ 10 s (yes or no)		No	
	FDP flaming > 10 s (yes or no)		No	



Wira House, West Park Ring Road, Leeds, LS16 6QL, UK.

Telephone: +44 (0) 113 259 1999

Email: info@bttg.co.uk

Website: www.bttg.co.uk

Date: 20 September 2018

Our Ref: 27/04729B/08/18

Your Ref:

Page: 4 of 6

Client: GTECH Strategies Limited

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with BS EN 13501-1:2007+A1:2009.

4.2 Classification

The product 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard, in relation to its reaction to fire behaviour is classified:

C

The additional classification in relation to smoke is:

s1

The additional classification in relation to flaming droplets / particles is:

d0



1066

Shirley® Technologies Limited. Registered Office: Wira House, West Park Ring Road, Leeds, LS16 6QL.
A company registered in England & Wales with company number 04669651. VAT Number GB 816764800.

BTTG™ and Shirley® are trade names of Shirley Technologies Limited.

The supply of all goods and services is subject to our standard terms of business, copies of which are available on request.
Our laboratories are accredited to EN ISO/IEC 17025.

Copyright © 2016 Shirley Technologies Limited. All rights reserved.

Date: 20 September 2018

Our Ref: 27/04729B/08/18
Your Ref:

Page: 5 of 6

Client: GTECH Strategies Limited

4.2 Classification (continued)

Fire behaviour		Smoke production			Flaming droplets	
C	-	s	1	-	d	0

Reaction to fire classification: C s1 d0

4.3 Field of application

This classification is valid for the following product parameters:

Reference: 'DFP 8000 Ultra Tack White' film on 12.5mm gypsum plasterboard
Manufacturer: Arlon Graphics LLC, USA.
Product Type: Wallcovering

The classification is valid for the following end use applications:

The sample was tested as received which was adhered to a 12.5mm gypsum plasterboard.



1066

Shirley® Technologies Limited. Registered Office: Wira House, West Park Ring Road, Leeds, LS16 6QL.
A company registered in England & Wales with company number 04669651. VAT Number GB 816764800.

BTTG™ and Shirley® are trade names of Shirley Technologies Limited.
The supply of all goods and services is subject to our standard terms of business, copies of which are available on request.
Our laboratories are accredited to EN ISO/IEC 17025.

Copyright © 2016 Shirley Technologies Limited. All rights reserved.

Date: 20 September 2018

Our Ref: 27/04729B/08/18

Your Ref:

Page: 6 of 6

Client: GTECH Strategies Limited

5 Limitations

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested."


An estimation of uncertainty of measurement has not been taken into account when making a judgement to any pass/fail criteria.

B Marsden

SIGNED

B Marsden

Fire Technician



APPROVED

P Doherty

Operational Head



1066